

RESEARCH-DEVELOPMENT AND TESTING NATIONAL
INSTITUTE FOR ELECTRICAL ENGINEERING

ICMET CRAIOVA
HIGH VOLTAGE DIVISION

Force Testing Laboratory - FTL

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number RO387 1599
Phone: + 40 0351 402425, 404888; Fax: + 40 0351 404890
www.icmet.ro ; E-mail: market@icmet.ro

TEST REPORT
No. 1986/ 01.08.2013

- | | |
|----------------------------|--|
| 1. CUSTOMER: | SCHIRTEC AG
Ignaz – Köck Strasse 10, A–1210 Wien, Austria |
| 2. MANUFACTURER: | SCHIRTEC AG
Ignaz – Köck Strasse 10, A–1210 Wien, Austria |
| 3. TESTED PRODUCT: | Early Streamer Emission (E.S.E.) Lightning
Conductor, type SCHIRTEC – AS (S-AS) |
| 4. TEST STANDARD: | NFC 17-102:2011, Annex C 3.1, 3.2
UNE 21186:2011, Anexo C |
| 5. PERFORMED TESTS: | I. Documentary information and identification
II. Marking
III. Mechanical test |
| 6. TEST DATE: | 31.07.2013 |
| 7. TEST RESULTS: | The product passed the tests |

The report has 8 pages and is edited in 4 copies, copy no.1 remain in laboratory and copies no. 2, no. 3 and no. 4 are sent to the customer.

HEAD OF HIGH VOLTAGE DIVISION,
Dipl. Eng. Ion Pătru

Ion Pătru



- a. The results refer only to the tested product.
- b. Publication and reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of laboratory.
- c. All signatures of the present report are original ones.



Content	page
1. Identification of the test product	3
2. Technical characteristics established by manufacturer	3
3. Tests program	3
4. Responsible for test	3
5. Checking	3
6. Tests description and test results presentation	4...6
7. Annexes	7...8



1. Identification of the test product: E.S.E. Lightning Conductor

Type: SCHIRTEC – AS (S-AS)

Serial / year: Prototype/2013

Technical Specification / Drawing: see page 8

Contract / Test order: 705.2/ 8044/16.05.2013

Internal test order: 22160/20.05.2013

Product receiving date: 31.07.2013

Product condition at receiving: New

2. Technical characteristics established by manufacturer:


Early ionization time period $\Delta T \dots 30 \mu s$


3. Test program:

I. Documentary information and identification

II. Marking

III. Mechanical test

4. Responsible for test: Dipl. Eng. R. Georgescu (I, II, III) 

5. Checking by: Dipl. Eng. I. Dinu 

I – DOCUMENTARY INFORMATION AND IDENTIFICATION

1. Test date: 31.07.2013

2. Atmospheric conditions: $p = 982\text{mbar}$; $t = 25^{\circ}\text{C}$; $h_r = 55\%$

2. Test standard: NFC 17-102:2011, Annex C, 3.1.1

4. Test set-up / test plan: –

5. Working mode:

SCHIRTEC – AS Early Streamer Emission Lighting Conductor was identified by the information indicated on the product marking (Photo 1) and by the technical documentation.

- Name (logo and trade mark) of the manufacturer: SCHIRTEC

- Product reference:

- Model: E.S.E.
- Type: SCHIRTEC – AS (S-AS)
- Reference standard: NFC 17-102:2011
- Early streamer emission efficiency ΔT (μs): 30
- Serial number: prototype/2013

6. Equipment and apparatus used: –

7. Measuring system (as necessary): –

Measuring uncertainty :

8. Conclusion/test results (as necessary):

The product passed the test.

II – MARKING

1. Test date: 31.07.2013

2. Atmospheric conditions: $p = 982\text{mbar}$; $t = 25^{\circ}\text{C}$; $h_r = 55\%$

2. Test standard: NFC 17-102:2011, Annex C, 3.1.2

4. Test set-up / test plan: –

5. Working mode:

The test was carried out by rubbing the marking by hand for 15s with a cotton rag dipped in water and for 15s more with a cotton rag dipped in hexane aliphatic.

After the test the marking was checked. It was legible.

6. Equipment and apparatus used:

- cotton rag
- water
- hexane aliphatic

7. Measuring system (as necessary): –

8. Conclusion/test results:

After the test the marking was legible.

The product passed the test.

III – MECHANICAL TEST

1. Test date: 31.07.2013

2. Atmospheric conditions: p = 982mbar; t = 25⁰C; h_r = 55%

2. Test standard: NFC 17-102:2011, Annex C, 3.2

4. Test set-up / test plan:

The test was performed inside the laboratory, in normal environmental conditions, at the daylight.

5. Working mode:

The dimensions of the product were measured and the values were recorded.

Then it was checked the concordance with the dimensions from the drawing attached.

The data are presented in Table 1.

Table 1

Dimension acc. to the drawing (mm)	Measured dimension (mm)
115 ± 1	115.4
Φ30 ± 1	Φ30.06
230 ± 3	231.00
Φ24 ± 1	Φ23.98
147 ± 1	147.00
34 ± 1	33.46
186 ± 4	185.00
4 ± 1	4.00
8 ± 1	8.00

6. Equipment and apparatus used:

- electronic termohygrograph EE 23, serial no. 0409/P23123.007, manufacturer E+E Elektronik – Austria, c.c. no. DJ 005084.578/2013 (DRML Craiova), measurement uncertainty 0.4⁰C (for coverage factor k = 2 and confidence level ρ = 95%)

7. Measuring system:

- digital caliper, serial no. 5V0064501, manufactured by TESA – Switzerland, c.c. no. DJ-017-162-833/2013, expanded uncertainty U = 0.02mm for k = 2

8. Conclusion/test results (as necessary):

The differences between measured dimensions and the dimensions in the drawing are less the specified tolerances.

The product passed the test.



Photo 1

