



RESEARCH, DEVELOPMENT AND TESTING NATIONAL INSTITUTE FOR ELECTRICAL ENGINEERING – ICMET CRAIOVA

HIGH VOLTAGE DIVISION – HVD FORCE TESTING LABORATORY – FTL

200746 Craiova, B.dul Decebal Nr. 118 A Registering Certificate: J16/312/1999; VAT no.: RO3871599 Phone: +40 351 404888, +40 351 402425; Fax: +40 351 404890, +40 251 415482

Testing Laboratories: RENAR LI 450: High Voltage + EMC RENAR LI 004: High Power RENAR LI 529: Low Voltage

TEST REPORT No. 1967/ 06.12.2012

- 1. Product: E.S.E Lightning Conductor, type Schirtec - DA
2. Tests: 1. Documentary information and identification 2. Marking 3. Mechanical tests
3. Order: Contract no. 705.2/ 7946/ 20.09.2012
4. Customer: SCHIRTEC AG Ignaz-Köck Strasse 10 A – 1210 Wien Austria
5. Manufacturer: SCHIRTEC AG Ignaz-Köck Strasse 10 A – 1210 Wien Austria
6. Reference Standard: NFC 17-102:2011, Annex C 3.1; 3.2
7. Testing date: 05.12.2012
8. Responsible for tests: Dipl.Eng. Dinu Ion
9. Test Result: Product passed the test
10. This Test Report contains 5 pages and it is edited in 4 copies: 1 for HVD and 3 for the customer

Head of HVD, Dipl.Eng. Ion PATRU (with signature and ICMET stamp)

CAUTION : a) Results refer to test product only. b) Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to. c) All the signatures of this Test Report are in original ones.



HVD

1. Documentary information and identification (NFC 17 – 102: 2011, Annex C, 3.1.1)

1.1. Product receipt date: 03.12.2012

1.2. Test date: 05.12.2012

1.3. Environmental conditions during the test:

- temperature: $+19^{\circ}\text{C} \pm 1^{\circ}\text{C}$;
- relative humidity: $50\% \pm 3\%$.

1.4. Test and measurement equipment: -

1.5. Testing procedure:

SCHIRTEC – A Early Streamer Emmision Lightning Conductor (Fig. 1) was identified by the information indicated on the product marking (Photo. 1) and by the technical documentation.

- Name (logo and trade mark) of the manufacturer: SCHIRTEC
- Product reference:
 - Model: E.S.E.
 - Type: S – DA
 - Reference standard: NFC 17 – 102: 2011
 - Early streamer emmision efficiency $\Delta T(\mu\text{s})$: 60
 - Serial number: prototype

1.6. Test result: The product passed the test




Fig. 1




Photo 1



HVD

TEST REPORT No. 1967

Page 3/5

2. Marking

(NFC 17 – 102: 2011, Annex C, 3.1.2)

2.1. Product receipt date: 03.12.2012

2.2. Test date: 05.12.2012

2.3. Environmental conditions during the test:

- temperature: $+19^{\circ}\text{C} \pm 1^{\circ}\text{C}$;
- relative humidity: $50\% \pm 3\%$.

2.4. Test and measurement equipment:

- cotton rag;
- water;
- hexane aliphatic.

2.5. Testing procedure:

The test was carried out by rubbing the marking by hand for 15s with a cotton rag dipped in water and for 15s more with a cotton rag dipped in hexane aliphatic. After the test the marking was legible.

2.6. Test result: The product passed the test

3. Mechanical test

(NFC 17 – 102: 2011, Annex C, 3.2)

3.1. Product receipt date: 03.12.2012

3.2. Test date: 05.12.2012

3.3. Environmental conditions during the test:

- temperature: $+19^{\circ}\text{C} \pm 1^{\circ}\text{C}$;
- relative humidity: $50\% \pm 3\%$.

3.4. Test and measurement equipment:

- digital caliper, serial no. G111089, manufactured by PROFIX Poland, calibration certificate no. DJ 006-186 1085/ 2010



HVD

TEST REPORT No. 1967

Page 4/5

3.5. Testing procedure:

The test was carried out by checking of the dimensional characteristics with their tolerances, according to the manufactured drawings and data.

Using the digital caliper, there were measured the dimensions specified in the drawing no. SCH 103 (Annex). The measured values are presented in Table 1.

Table 1

Dimension acc. drawing (mm)	Measured dimension (mm)
148 ± 0.5	148.01
8 ± 0.5	7.98
140 ± 0.5	140.01
120 ± 0.5	120.02
85 ± 0.5	84.99
69 ± 0.5	69.3
8 ± 0.5	7.98
50 ± 0.5	50.01
61 ± 0.5	61.01
100 ± 0.5	100.02
140 ± 0.5	140.01
8 ± 0.5	7.98
140 ± 0.5	140.01
720 ± 0.5	720.03

3.6. Test result: The product passed the test



HVD

TEST REPORT No. 1967

Page 5/5

Annex

1	2	3	4														
TECHNICAL SPECIFICATIONS																	
		REV. NO.	DESCRIPTION														
		APPROVAL	REV. DATE														
A																	
B																	
C																	
D																	
E																	
F	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>NAME-SURNAME</th> <th>DATE</th> <th>SIGNATURE</th> </tr> <tr> <td>PREPARED BY</td> <td>06.02.2013</td> <td></td> </tr> <tr> <td>CONTROL</td> <td>06.02.2013</td> <td></td> </tr> <tr> <td>APPROVAL</td> <td>06.02.2013</td> <td></td> </tr> </table>	NAME-SURNAME	DATE	SIGNATURE	PREPARED BY	06.02.2013		CONTROL	06.02.2013		APPROVAL	06.02.2013					
NAME-SURNAME	DATE	SIGNATURE															
PREPARED BY	06.02.2013																
CONTROL	06.02.2013																
APPROVAL	06.02.2013																
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>MATERIAL</th> <th>WEIGHT</th> </tr> <tr> <td>MATERIAL STANDARD</td> <td></td> </tr> <tr> <td>COATING & PAINT</td> <td></td> </tr> </table>		MATERIAL	WEIGHT	MATERIAL STANDARD		COATING & PAINT		<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td colspan="2" style="text-align:center;">PART NAME</td> </tr> <tr> <td colspan="2" style="text-align:center;">SCHIRTEC_DA_(S-DA)</td> </tr> <tr> <td colspan="2" style="text-align:center;">PART NO / DRAWING NO</td> </tr> <tr> <td colspan="2" style="text-align:center;">SCH.103</td> </tr> </table>		PART NAME		SCHIRTEC_DA_(S-DA)		PART NO / DRAWING NO		SCH.103	
MATERIAL	WEIGHT																
MATERIAL STANDARD																	
COATING & PAINT																	
PART NAME																	
SCHIRTEC_DA_(S-DA)																	
PART NO / DRAWING NO																	
SCH.103																	
<ul style="list-style-type: none"> * UNIT OF MEASUREMENT : mm * NOT SPECIFIED IN THE DRAWING - TOLERANCES : - MEASUREMENT: ± 0,5 mm / ANGLE : ± 1 ° - SURFACE ROUGHNESS : 3,2 μm * FINISHED PARTS FREE OF DIRT AND BURR * MEASUREMENTS CANNOT BE TAKEN FROM THE DRAWING 		<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>ISSUE DATE</th> <th>SCALE</th> <th>PAGE</th> <th>SIZE</th> </tr> <tr> <td>06.02.2013</td> <td>1/1</td> <td>1</td> <td>A4-H</td> </tr> </table>	ISSUE DATE	SCALE	PAGE	SIZE	06.02.2013	1/1	1	A4-H							
ISSUE DATE	SCALE	PAGE	SIZE														
06.02.2013	1/1	1	A4-H														
ALL RIGHTS RESERVED, WITHOUT WRITTEN CONSENT, NONE OF THE DETAILS IN THIS DOCUMENT MAY BE COPIED, RECORDED, PRINTED OR DUPLICATED.																	
Rev No:		Rev Date:															
Issue Date: 16.06.2008		Page No: 1/1															

-End of Test Report -